



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 06/27/2019
Received: 06/20/2019
Sampled By: Kari Duncan
Work Order: 9171040

C **Springwater Academy**
L Attn: Kari Duncan
I 4260 Kenthorpe Way
E West Linn OR, 97068
N Phone: (503) 635-0393
T


Project: LCR
Project # : N/A
PWSID # : 4194043

Sampling Location: Springwater Academy

Lab Number

Code	Method	Units	Result	MRL	EPA MCL	Analysis Date/ Time
9171040-01 Sample Name: #1 Kitchen Matrix: Drinking Water Sampled: 6/20/19 7:45						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	06/25/19 12:45
A Lead	1030 EPA 200.9	mg/L	0.003	0.002	0.015	06/24/19 15:23
9171040-02 Sample Name: #2 Water Fountain Matrix: Drinking Water Sampled: 6/20/19 7:50						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	0.188	0.050	1.3	06/25/19 12:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/24/19 15:23
9171040-03 Sample Name: #3 Oakleaves Rm 1 Matrix: Drinking Water Sampled: 6/20/19 8:00						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	ND	0.050	1.3	06/25/19 12:45
A Lead	1030 EPA 200.9	mg/L	0.002	0.002	0.015	06/24/19 15:23
9171040-04 Sample Name: #4 Blue Heron Rm 5 Matrix: Drinking Water Sampled: 6/20/19 7:55						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	0.116	0.050	1.3	06/25/19 12:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/24/19 15:23
9171040-05 Sample Name: #5 River Otter Rm 11 Matrix: Drinking Water Sampled: 6/20/19 7:40						
<i>Metals (Total)</i>						
A Copper	1055 SM3111B	mg/L	0.130	0.050	1.3	06/25/19 12:45
A Lead	1030 EPA 200.9	mg/L	ND	0.002	0.015	06/24/19 15:23

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
A = All procedures for this analysis are accredited in accordance with NELAP standards. Lab Accreditation No. OR-100013

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director